



Addendum #1

TO: All Respondents

FROM: District of Sooke

DATE: November 8, 2017

PROJECT: **DC Fast Charge (DCFC)
Request for Proposal**

FILE NO: 2017-002

A. PRECEDENCE

1. This Addendum shall form an integral part of the Work. This Addendum shall take precedence over all requirements of the Tender Documents with which it may prove to be at variance unless otherwise qualified by the District.

B. PURPOSE

1. This addendum is in response to enquiries as per the Request for Quote document.

C. QUESTIONS

1. Can you confirm which day of the week (weekdays or weekends) and what time of day (during working hours or after) the electrical can be shut down to allow our electrical contractor to do his work.

Answer: This panel controls various lights on the street and the crosswalk and perhaps the BC Transit lights at the shelter. All of this must be confirmed by proponent. Daytime shutdown is preferred. Coordinate with the District.

2. What is the timeframe of the installation?

Answer: The timeframe desired is within 2017. However, if the estimate moves beyond the current budget, a review of a new timeline could be established early in the new year, dependent upon Council approvals of this budget item for 2018. Another DCFC station is proposed for 2018, therefore we could establish a program for both stations at that time.

3. The power to the site is 208V/3 phase. How do I propose a solution to get 480V/3 phase (if required)?

Answer: After the proponent check the constraints with BC Hydro regarding the costs and viability of modifying the existing transformers, the proponent may wish to perform calculations for the full build out of two 50kw DCFC, then highlight within the proposal which option with the best cost-benefit ratio. Alternatively, you may provide several options and associated costs.