

Owner: District of Sooke
(NAME OF OWNER)

Contract: 2018 Road Improvement Program
(TITLE OF CONTRACT)

Reference No. 2018_5400-10_01
(OWNER'S CONTRACT REFERENCE NO.)

To all Tenderers:

Date: April 4, 2018

This addendum shall form part of the original documents for the above noted contract and all other segments of the contract shall remain in force except as noted below:

APPENDIX 1: Schedule of Quantities and Prices
Section 32 01 11, Para 1.2.3 "Remove Pavement Markings"

The Tenderer shall list the Lump Sum Amount for this item as "**N/A**".
The Contractor will not be expected to remove pavement markings, and shall apply tack coat directly on top of any existing pavement markings as though the surface was bare asphalt.

SUPPLEMENTARY SPECIFICATIONS
Reference Section 32 12 16 Hot-Mix Asphalt Concrete Paving
3.3 Preparation
Add to End of Fourth Paragraph of Supplementary Clause 3.3.3

The Contractor may use steel riser rings to vertically adjust manhole lids. Steel riser rings do not require parging with cement mortar.

All tenderers shall acknowledge receipt of Addendum #1 (one (1) page) by signing in the space provided and submitting this signed addendum with the tender. Tenders submitted without acknowledgement of this addendum may be considered incomplete.

Receipt acknowledged and conditions agreed _____ day of _____, 2018

Tenderer

Signature

END OF ADDENDUM #1