



Stantec Consulting Ltd.
400 - 655 Tye Road,
Victoria, BC
V9A 6X5

Addendum – No. 1

Project No.:	111720015	Owner:	District of Sooke
Addendum No.:	1	Contract No.:	WWTP-2020
Date:	July 20, 2020		

Addendum issued to active tenderers with documents on record **(4 pages)**. *This addendum is to be read with and constitutes part of the tender document.*

The following changes to the Tender documents for District of Sooke Tender WWTP-2020 are issued by this Addendum No. 1.

INVITATION TO TENDERER

Delete:

Tender Closing Time: 3:00 p.m. local time in Sooke

Tender Closing Date: July 30th, 2020

Insert:

Tender Closing Time: 3:00 p.m. local time in Sooke

Tender Closing Date: August 7th, 2020

INSTRUCTIONS TO TENDERERS

SECTION 3 SUBMISSION OF TENDERS (page 3 of 8)

Delete:

Tender Closing Time: 3:00 p.m. local time in Sooke

Tender Closing Date: July 30th, 2020

Insert:

Tender Closing Time: 3:00 p.m. local time in Sooke

Tender Closing Date: August 7th, 2020

SPECIFICATION CHANGES

Specification Section 22 11 00 Domestic Water

2.1 Pipe and Fitting

2.1 (page 1 of 5)

3.1 General

3.1.1 (page 3 of 5)

Specification Section 40 05.15 Process Piping and Appurtenances

2.1 Pipe Material

2.1.1 PVC Piping

2.1.1.1 (page 1 of 3)

2.1.1.2 (page 1 of 3)

Delete:

Schedule 40 for all Specification Sections referenced above

Insert:

Schedule 80 for all Specification Sections referenced above

Specification Section 24 14 00 Control Panels

2.6 Programable Logic Controllers

Delete:

2.6.3. Acceptable programmers will be integrators local to Vancouver Island with experience with WWTPs and The District work.

Insert:

2.6.3. MPE Engineering Ltd. shall be retained by the Contractor for all SCADA programming work required for the project.

MPE Engineering Ltd
7990 Greendale Rd.
P.O. Box 1854
Lake Cowichan, BC
V0R 2G0

Contact Information
Phone: 250-709-0218

2.7 Human Machine Interface

Delete:

2.7.2. "Acceptable programmers will be the PLC programmers"

Insert:

2.7.2. "MPE Engineering Ltd. will be the PLC programmers"

Specification Section 26 05 01 Common Work Results for Electrical

1.7 Permits, Fees, and Inspection

1.7.1

Delete:

Town of Lake Cowichan

Insert:

District of Sooke

QUESTIONS AND ANSWERS

1. Contractor Questions:

1.1. Trittech would like to request a two-week extension of the Tender closing date from Thursday, July 30th to Thursday, August 13, 2020.

Refer to Tender Closing date changes shown on page 1 of this Addendum No. 1.

1.2. Can you confirm if there will be a site walk through for this project?

An "optional" site walk through will be provided to interested bidders:

Location: Sooke Wastewater Plant

Date: Friday July 24th, 2020

Time 1:00 pm

Please RSVP to stan.spencer@stantec.com



Stantec Consulting Ltd.



Prepared by: **Stan Spencer, P. Eng.**
Process Mechanical Lead
Phone: (250) 389-2376
Fax: (250) 382-0514
stan.spencer@stantec.com

Distribution:
Project Team, Bidders