Stantec Consulting Ltd.
400 - 655 Tyee Road,
Victoria, BC
V9A 6X5

Addendum – No. 6

Project No.:	111720015	Owner:	District of Sooke
Addendum No.:	**6**	Contract No.:	WWTP-2020
Date:	August 18, 2020		

Addendum issued to active tenderers with documents on record **(1 pages).** *This addendum is to be read with and constitutes part of the tender document.*

The following RFI responses to the Tender documents for District of Sooke Tender WWTP-2020 are

1. QUESTIONS AND ANSWERS

Q1 Item 23 on P-604 identifies a 150 mm (6") static mixer. I can find specs on a ¾" Static Mixer but I have not been able to find anything on a 6" Static Mixer.

KoFlo Corporation Clear PVC Static Mixer or equivalent is an acceptable standard.

Q2 We have noticed that the year on page 6 and 7 the tender forms needs to be changed to 2020.

Also, same issue on the Addendum 4 version of the Novation Agreement (page 7 of 8).

Dates should reference 2020.

2. NOTICE RE: TENDER QUESTIONS

No more questions or enquiries or schedule extensions will be allowed for this tender. This is the final addendum.

Stantec Consulting Ltd. Prepared by: **Shaun Swarbrick, P. Eng.** Project Manager Phone: (250) 507-5876 Shaun.swarbrick@stantec.com	