

TO: All Tenderers

FROM: McElhanney Ltd.

DATE: June 25, 2021

PROJECT: Church Road Improvements – Sooke Road to Wadams Way - Tender

FILE NO: 2241-20128-00

1. PRECEDENCE

1. This Addendum shall form an integral part of the Work. This Addendum shall take precedence over all requirements of the Tender Documents with which it may prove to be at variance unless otherwise qualified by McElhanney.

2. PURPOSE

1. This addendum is in response to questions and requested clarifications received during the tender period.
2. This addendum provides additional information and instructions to the bidders.

3. INSTRUCTIONS

1. Additional Information and Instructions

- a. Gas line relocation will be required from approx. 10+110 to 10+170 to avoid streetlighting conflicts (see images below) – gas will be relocated approx. 0.5m east by Fortis. Fortis has indicated work would be completed in the fall so this portion of streetlighting, water meter adjustment and sidewalk construction will occur after relocation. It is expected that the contractor will construct curb and gutter and will provide a temporary gravel sidewalk and driveway access until final construction occurs.

Addendum #2

- b. There will not be a public opening of tenders. The successful Tenderer will be advised in writing by the District

2. Questions

- a. Can you please clarify what “facilitate” means when it comes to water items on Church Rd? Are we to just coordinate with CRD to schedule the work, or are we to support CRD forces with excavation/backfill/traffic control?
 - i. **Contractor is to coordinate the work with CRD and complete excavation, backfill and traffic control.**