



Date: August 13, 2021

RFP2021-WW002

**WASTEWATER TREATMENT PLANT EXPANSION
DESIGN, CONTRACT ADMINISTRATION, &
PROJECT MANAGEMENT SERVICES**

Addendum No. 2

2.1	<p>1- Question: Section 3.4.1.b states that: <i>“The successful Proponent will be required to optimize the preliminary design to ensure any components of the WWTP that require to be upgraded in conjunction with the components identified within the Preliminary scope are captured prior to proceeding to final design. This may include but is not limited to the following upgrades: headworks, Ultraviolet (UV) disinfection, Electrical, Motor Control Centre, Programmable Logistic Controllers (PLC), SCADA, Blowers, Generator, Mechanical, Structural, and Plumbing.”</i> If there are any additional upgrades deemed necessary during the preliminary design and servicing report beyond those mentioned in Section 3.4.1.c, it is assumed that any required subsequent activities such as final design, procurement and construction support are not part of the fee schedule evaluation in this RFP. Please confirm if our understanding is correct.</p> <p>Response: Yes, your understanding is correct.</p>
2.2	<p>1- Question: Please confirm that the latest process modelling native file (reflecting the current operation), and native files of the project drawings will be provided by the District to the successful proponent.</p> <p>Response: Yes, any information that the District of Sooke has will be provided to the successful proponent.</p>
2.3	<p>1- Question: Section 4.5 states that: <i>“Respondents shall provide the names, position titles, and contact telephone and/or e-mail of three (3) persons who can provide references for the projects listed pursuant to section 4.4 above.”</i></p> <p>It is interpreted that the RFP is asking for 1 client contact for each of the 3 project references. Please confirm if our understanding is correct.</p>

	<p>Response : Yes, your understanding is correct</p>
2.4	<p>Question: The RFP indicates hard copy is required. Please confirm if hard copy is required or if submissions can be made electronically.</p> <p>Response: Hard copies are required.</p>
2.5	<p>Question: Several requests for a one- or two-week extension to the above RFP</p> <p>Response: Please see Addendum 1. Closing date will remain August 19th, 2021.</p>
2.6	<p>Question: Where are the solids for the screw in headworks deposited?</p> <p>Response: The solids are separated and deposited into a bin located below the headworks building then hauled to the heartland landfill.</p>
2.7	<p>Question: What is done if any archaeological remains are discovered?</p> <p>Response: Work are to cease, and BC Archaeological Branch will be contacted by the District and direction from Archaeological Branch from the Ministry of Forest, Lands, Natural Resource Operations and Rural Development and provided to the successful proponent by the District.</p>